



JOHN ELIAS BALDACCI  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE  
04333-0016

DAVID A. COLE  
COMMISSIONER

April 7, 2009  
Subject: **Augusta Lighting**  
Federal Project Number: IM-1598(300)E  
PIN: 015983.00  
**Bid Amendment No. 1**

Dear Sir/Ms.:

The following questions have been received:

**Question:** Sheet #2, General Notes #7 states that you are using Halphane Luminaries. The Catalog numbers are not listed on the drawings, could you supply them?

**Response:** Luminaire catalog number is: Holophane Mongoose G 250 HP 48 L W F V G B P F2 (IES Test No. 49395)

**Question:** The base detail shows 24 in. diameter but no length?

**Response:** Pole base dimensions are 24 inch diameter x 7 Ft. deep and shall comply with MDOT standard detail 626.02.

**Question:** No dimension or supplies are given for hand holes?

**Response:** Handholes shall be in accordance with MDOT standard detail 626 (09) Rev. Feb. 23, 2005 titled "Electrical Junction Box for Traffic Signals and Lighting" with dimensions of approximately 25" long x 16" wide x 18" deep, CDR systems Corp. A12-1324-18 or approved equal.

**NOTE:** Standard Details may be viewed through our web site, [http://www.maine.gov/mdot/contractor-consultant-information/contractor\\_cons.php](http://www.maine.gov/mdot/contractor-consultant-information/contractor_cons.php) or may be purchased by calling 207-624-3220.

Consider this information prior to submitting your bid on April 15, 2009.

Sincerely,

Scott Bickford  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER